

ਦਫ਼ਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਜਲ ਸਪਲਾਈ ਅਤੇ
ਸੈਨੀਟੇਸ਼ਨ, ਉਪ ਮੰਡਲ ਨੰ. 1, ਫਰੀਦਕੋਟ

ਵੱਲ,

ਦਿੱਲੀ ਇੰਟਰਨੈਸ਼ਨਲ ਸਕੂਲ,
ਕੋਟਕਪੂਰਾ ਰੋਡ, ਫਰੀਦਕੋਟ।


ਨੰ: 935


ਮਿਤੀ: 19-09-2022

ਵਿਸ਼ਾ:-

ਸਕੂਲ ਦੇ ਪੀਣ ਵਾਲੇ ਪਾਣੀ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਦੇ ਸਬੰਧ ਵਿੱਚ ਇਸ ਦਫ਼ਤਰ ਦੇ ਜੂਨੀਅਰ ਇੰਜੀਨੀਅਰ ਵੱਲੋਂ ਪਾਣੀ
ਦਾ ਸੈਂਪਲ ਇੱਕਤਰ ਕਰਨ ਉਪਰੰਤ ਅਤੇ ਇਸ ਦਫ਼ਤਰ ਦੇ ਲੈਬ ਕੈਮਿਸਟ ਤੋਂ ਪਾਣੀ ਦਾ ਨਮੂਨਾ(ਸੈਂਪਲ)
ਚੈਕ ਕਰਨ ਉਪਰੰਤ ਵੱਲੋਂ ਪੇਸ਼ ਕੀਤੀ ਰਿਪੋਰਟ ਅਨੁਸਾਰ ਪਾਣੀ ਦਾ ਸੈਂਪਲ ਪੀਣ ਯੋਗ ਪਾਇਆ ਗਿਆ
ਹੈ। ਸੋ ਇਸ ਲਈ ਇਹ ਤਸਦੀਕ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ ਤੁਹਾਡੇ ਸਕੂਲ ਦਾ ਪਾਣੀ ਪੀਣ ਯੋਗ ਅਤੇ
ਸਹੀ ਹੈ।


ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ,
ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਨੰ.1,
ਫਰੀਦਕੋਟ।


Principal
Delhi International School
Kotkapura Road, Faridkot
CBSE Aff. No. 1630452
School Code: 20439

DISTRICT WATER TESTING LABORATORY, FARIDKOT

Department of water supply and sanitation, Ghanalya Chowk, Opposite Khalsa sr. sec. school, Faridkot
dwtlfdk@gmail.com

TO,

Delhi International School
KOTKAPURA ROAD FDK


No.: DWTL/FDK/2223/00071 Dated : 19/09/2022

Subject : Testing Reports of Water Samples.


Reference: Your Letter/SRF No. 5038 Dated: 08/09/2022

As per above cited subject and reference, please find enclosed here with the report of 1 Water sample received on dated 15/09/2022. It is request to fill the attached feedback form and send it back to District water Testing Laboratory, Faridkot

D/A : Test Report



Authorized Signatory
For, District water Testing Laboratory,
Faridkot



Principal
Delhi International School
Kotkapura Road, Faridkot
CBSE Aff. No. 1630452
School Code: 20439

DISTRICT WATER TESTING LABORATORY, FARIDKOT
Department of water supply and sanitation, Ghanalya Chowk, Opposite Khalsa sr. sec. school, Faridkot
dwtlfdk@gmail.com

TEST REPORT


Name & Address of Customer : Delhi International School KOTKAPURA ROAD FDK		Customer Reference No.	No : 5038 Dated : 08/09/2022
		Sample Submitted by	JASKARAN SINGH
		Date of Sample Receipt	15/09/2022
		Analysis Starting Date	16/09/2022
		Analysis completion Date	17/09/2022
Discipline : Chemical Testing		Group: Water	
Test Report No.:	DWTL/FDK/2223/00071	Date of Issue :	19/09/2022
Registration no.:	DWTL/FDK/REG2223/00160	Condition of Sample :	Sealed
Source :	NA	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme :	NA	Location/Depth :	DELHI INTERNATIONAL SCHOOL FDK / NA
Village :	Faridkot Rural	Habitation :	Faridkot Rural
Block:	Faridkot	District :	Faridkot
Latitude :	NA	Longitude:	NA

Sample Type: Treated Water

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.25	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1	5	15	Hazen	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Disagreeable	--	IS 3025 (Part 5 - 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Disagreeable	--	IS 3025 (Part 8 - 1984) (RA 2017)
5	TDS	140	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
6	Turbidity	0.7	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
7	Alkalinity	52	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
8	Hardness	80	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
9	Calcium	24	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	4	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
11	Chloride	18	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. * Value not available or test not performed for this parameter.


Principal
Delhi International School
Kotkapura Road, Faridkot
CBSE Aff. No. 1630452
School Code: 20439

Mrs. Manju
Quality Manager
Authorized Signatory
For, District water Testing Laboratory,
Faridkot